Certificate of Compliance

Certificate Number **20080304 - E318982**

Report Reference E318982 - 2008 February 15

Issue Date 2008 March 4



Issued to:

GI PE ELETTROMECCANICA S A S

VIA DANIMARCA 8/D

20093 COLOGNO MONZESE MI ITALY

This is to certify that representative samples of

COMPONENT - SYSTEMS, ELECTRICAL INSULATION

Class 155(F) insulation system designated GIPE2008

Have been investigated by Underwriters Laboratories Inc. (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate..

Standard(s) for Safety:

UL 1446 - STANDARD FOR SYSTEMS OF INSULATING MATERIALS - GENERAL

Edition - 6

CSA C22.2 NO. 0 - GENERAL REQUIREMENTS -- CANADIAN ELECTRICAL

CODE, PART II Edition - 8

Additional Information:

System Designation GIPE2008
Insulation Class 155(F)
Maximum Hot Spote Temperature 155
Indoor Yes
Outdoor (Enclosed) Yes

Only those products bearing the UL Recognized Component Marks for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Mark for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark: **N, may be used in conjuction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Mark for Canada consists of the UL Recognized Mark for Canada: **N and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory.

Look for the UL Recognized Component Mark on the product

Issued by: Rita Chiodini
Rita Chiodini, Project Engineer
Underwriters Laboratories Inc.

Reviewed by: Sander Nieuwenhuijzen
Sander Nieuwenhuijzen, Engineering Team Leader
Underwriters Laboratories Inc.